

**ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION**

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org

**TEST REPORT****SHEET NO.: 1 OF 9**

NAME & ADDRESS OF CUSTOMER M/s. Epoxy Terminal & Equipment Pvt. Ltd. Plot No : 6B, Phase -III APIIC, IDA, Pashamylaram, Medak, Telangana India 502 307	REPORT NO.: RP-1819-017987 DATE : 07/08/2018	
	CUSTOMER REF. NO.: NIL DATED : 08/06/2018	
	DATE OF SAMPLE RECEIPT	DATE OF TESTING
	08/06/2018	02/07/2018 to 27/07/2018
SAMPLE DESCRIPTION 1.1 kV 630 A L.T Transformer Bushing Rated Voltage : 1.1kV Rated Current : 630 A Embossing : ETE	SAMPLE IDENTIFICATION Serial No. : 11/230518/B Make : M/s. Epoxy Terminal & Equipment Pvt. Ltd. Year of Mfg.: 2018 ERDA S.C. No.: ERDA-00261840	
TEST DETAIL As per SHEET NO.: 2 OF 9 ENCLOSURES:DRG. No.: ETB-0002REV 1 TEST WITNESSED BY: Mr. Ulpesh Parmar - M/s. Epoxy Terminal & Equipment Pvt. Ltd. REMARKS: As per SHEET NO.: 3 OF 9 to 8 OF 9		
TEST SPECIFICATION As per customer requirement & test procedure followed as per IS: 2099 - 1986		
 PREPARED BY	 CHECKED BY	 A.S. Khopkar APPROVED BY
Note : 1. This report relates only to the particular sample received in good condition for testing at ERDA. 2. This report cannot be reproduced in part under any circumstances. 3. Publication of this report requires prior permission in writing from Director, ERDA. 4. Only the tests asked for by the customer have been carried out. 5. In case of any dispute, Vadodara will be the exclusive jurisdiction & shall be construed as where the cause has arisen. Caution: ERDA is not responsible for the authenticity of photocopied or reproduced test reports. ERDA provides support to customers for verification of the authenticity of test reports issued by ERDA.		

TC 2576040



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1819-017987

SHEET NO.: 2 OF 9

DATE : 07/08/2018

TEST DETAIL :

1 Routine Test before type test.

- 1.1 Dry power-frequency withstand voltage test
- 1.2 Measurement of partial discharge quantity

2 Type test

- 2.1 Wet Power Frequency Voltage withstand test
- 2.2 Dry lightning impulse voltage withstand test
- 2.3 Cantilever load Withstand Test

3 Routine Test after type test

- 3.1 Dry power-frequency withstand voltage test
- 3.2 Measurement of partial discharge quantity

S.M.

PREPARED BY



[Signature]

CHECKED BY

TC 2582266

**ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION**

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org

**REPORT NO.:** RP-1819-017987**SHEET NO.:** 3 OF 9**DATE** : 07/08/2018**Routine Test before type test**

Sr. No.	Test Conducted (Cl.No. & IS)	Test Requirement	Obtained Results	Remark
Atmospheric condition:		Dry bulb Temperature : 29.0 °C Wet bulb Temperature : 24.0 °C Atmospheric Pressure : 741.2 mm of Hg		
1.1	Dry power frequency withstand voltage test (As per customer requirement & test procedure followed as per cl. no. 11.13 of IS: 2099 - 1986)	The power frequency voltage of 5 kVrms shall be applied between the H.V. terminal of bushing & earth. The test duration shall be 60s. No flashover or puncture shall be occurred during the test.	The power frequency voltage of 5 kVrms was applied between the H.V. terminal of bushing & earth. The test duration was 60s. No flashover or puncture was occurred during the test.	Conforms
1.2	Measurement of partial discharge quantity (As per customer requirement & test procedure followed as per cl. no. 11.14 of IS: 2099 - 1986) Measurement of partial discharge quantity shall be carried out - At $1.5U_m/\sqrt{3} = 0.6$ kV - At $1.05U_m/\sqrt{3} = 1.2$ kV	Max. 10 pC Max. 100 pC	01 pC 01 pC	Conforms Conforms

PREPARED BY**CHECKED BY**

TC 2582267



Certificate No.: TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodra-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1819-017987

SHEET NO.: 4 OF 9

DATE : 07/08/2018

Atmospheric condition :

Dry bulb Temperature	: 29.0 °C
Wet bulb Temperature	: 24.0 °C
Atmospheric Pressure	: 741.2 mm of Hg

2.1 Wet Power Frequency Voltage withstand test

(As per customer requirement & test procedure followed as per cl. no. 11.3 of IS: 2099 - 1986)

Test requirement:

The test Voltage of 5 kVrms corrected to reference atmospheric condition is applied between the H.V. terminals & earth for one minute duration under artificial rainfall condition.

REMARKS: Conforms.

2.2 Dry lightning impulse voltage withstand test

(As per customer requirement & test procedure followed as per cl. no. 11. 4 of IS: 2099 - 1986)

Test Parameters:

Rated Voltage : 1.1 kV
Test Voltage : 20 kVp \pm 3%
No. of Shots to be applied: 15 +ve & 15 -ve Polarity shots

Test Observation:

Calibration Pulse : 12.063 kVp, Wave Shape: 1.256 / 47.805 μ s
No. of Shots applied : Calibration pulse, 15 +ve & 15 -ve Polarity shots
No. of Shots recorded : Calibration pulse, First & Last shot (for both polarity)

No. of Shot	Test Voltage Applied in kVp	
	Positive Polarity	Negative Polarity
1.	20.351	20.183
2.	20.393	20.031
3.	19.550	20.076
4.	20.272	19.833
5.	19.768	20.186
6.	19.708	20.385
7.	19.750	19.809
8.	20.475	19.947
9.	19.661	20.025
10.	19.992	20.305
11.	20.258	20.424
12.	19.726	20.145
13.	19.906	20.178
14.	19.942	20.170
15.	20.402	20.134

REMARKS: Conforms.

PREPARED BY

CHECKED BY



TC 2582281



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org




TEST REPORT NO. : RP-1819-017987

SHEET NO.: 5 of 9

DATE : 07/08/2018

DRY LIGHTNING IMPULSE VOLTAGE WITHSTAND TEST



CALIBRATION PULSE

$U_p = 12.06 \text{ kV}$

$T_1 = 1.26 \mu\text{s}$

$T_2 = 47.80 \mu\text{s}$

$T_c = \mu\text{s}$

Comment: LI RW

S.M.

PREPARED BY



CHECKED BY

TC 2582275




ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION
(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.
EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33
Fax : +91 (0265) 2638382
E-mail : erda@erda.org
Web : http://www.erda.org



TEST REPORT NO. : RP-1819-017987
DATE : 07/08/2018


SHEET NO.: 6 of 9

DRY LIGHTNING IMPULSE VOLTAGE WITHSTAND TEST




Comment: 100% LI FW

FIRST SHOT
 $U_p = 20.35 \text{ kV}$
 $T_1 = 1.25 \mu\text{s}$
 $T_2 = 48.38 \mu\text{s}$
 $T_c = \mu\text{s}$




Comment: 100% LI FW

LAST SHOT
 $U_p = 20.40 \text{ kV}$
 $T_1 = 1.25 \mu\text{s}$
 $T_2 = 48.38 \mu\text{s}$
 $T_c = \mu\text{s}$



Comment: 100% LI FW

FIRST SHOT
 $U_p = -20.18 \text{ kV}$
 $T_1 = 1.25 \mu\text{s}$
 $T_2 = 47.93 \mu\text{s}$
 $T_c = \mu\text{s}$



Comment: 100% LI FW

LAST SHOT
 $U_p = -20.13 \text{ kV}$
 $T_1 = 1.25 \mu\text{s}$
 $T_2 = 47.88 \mu\text{s}$
 $T_c = \mu\text{s}$

TC 2582276

PREPARED BY



CHECKED BY



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.



EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO: RP-1819-017987			SHEET No. 7 OF 9	
DATE : 07/08/2018				
Sr. No.	Particular of Tests & Cl. No.	Requirement as per Specification	Obtained Value/ Observation	Remarks
2.3	Cantilever load withstand test [Cl. No. 11.10 of IS 2099 & as per customer's requirement] (The load of 1000 N* applied perpendicular to the axis of the bushing at the mid-point of the terminal for one minute) ERDA-00261840	The bushing shall be considered to have passed the test if there is no evidence of damage (deformation or rupture) and if it has withstood a repetition of routine tests without significant change from previous results.	No evidence of damage was observed in bushing and bushing withstood repetition of routine tests (Dry power frequency withstand voltage test and Measurement of partial discharge quantity) without any significant change from previous results.	Conforms
Note: "*" As specified by customer.				
 PREPARED BY		 CHECKED BY		



TC 2579303

**ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION**

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org

**REPORT NO.:** RP-1819-017987**SHEET NO.:** 8 OF 9**DATE** : 07/08/2018**Routine Test after type test**

Sr. No.	Test Conducted (Cl. No. & IS)	Test Requirement	Obtained Results	Remarks
Atmospheric condition:		Dry bulb Temperature : 29.0 °C Wet bulb Temperature : 25.0 °C Atmospheric Pressure : 743.2 mm of Hg		
3.1	Dry power frequency withstand voltage test (As per customer requirement & test procedure followed as per cl. no. 11.13 of IS: 2099 - 1986)	The power frequency voltage of 5 kVrms shall be applied between the H.V. terminal of bushing & earth. The test duration shall be 60s. No flashover or puncture shall be occurred during the test.	The power frequency voltage of 5 kVrms was applied between the H.V. terminal of bushing & earth. The test duration was 60s. No flashover or puncture was occurred during the test.	Conforms
3.2	Measurement of partial discharge quantity (As per customer requirement & test procedure followed as per cl. no. 11.14 of IS: 2099 - 1986) Measurement of partial discharge quantity shall be carried out - At $1.5U_m/\sqrt{3} = 0.6$ kV - At $1.05U_m/\sqrt{3} = 1.2$ kV	Max. 10 pC Max. 100 pC	01 pC 01 pC	Conforms Conforms
	Change in measurement of partial discharge quantity Change in partial discharge quantity - At $1.5U_m/\sqrt{3} = 0.6$ kV - At $1.05U_m/\sqrt{3} = 1.2$ kV	≤ 05 pC# ≤ 05 pC#	0 pC 0 pC	Conforms Conforms

Note: "#" Requirement of change in measurement of partial discharge quantity was specified by customer.**PREPARED BY****CHECKED BY**

TC 2582269



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO. : RP-1819-017987
DATE : 07/08/2018

SHEET NO.: 9 of 9

PHOTOGRAPH OF TEST SAMPLE



PHOTOGRAPH OF NAME PLATE



5/3


PREPARED BY



5/3

CHECKED BY

TC 2576037



CONTROLLED COPY

Test Report No. 89-189-077987
 Date: 07/08/2018
 Product: 1.1 Kv 630A L.T. X. max. Assembly
 Verified By: A.M.
 Verification of this drawing by ERDA is limited to relevant dimensional checks only.
 Verified dimensions are marked with *.

S.NO	Description	value	ITEM NO.	PART NUMBER	DESCRIPTION	QTY.
1	RATED VOLTAGE	1.1 Kv	detail 1	ETB 0002-1		1
2	one min.DRY FREQUENCY WITH STAND VOLTAGE	5.0 Kv	EPOXY TERMINAL AND EQUIPMENT PVT. LTD.			
3	CREEPAGE DISTANCE	*50 mm	PLOT 68, PHASE III, IDA PASHAMAILARAM, PATANCHERU, SANGAREDDY, TELANGANA - 502 307.			
4	MAX CURRENT	630A	Date: 09/02/2018			
5	COPPER FLAT DIMENSION TOLERANCE	IS 613-2008	Drawn by: PANKAJ			
6	COPPER AND EPOXY DIMENSION TOLERANCE	IS 2102-1993	Checked by: RK			
7	ELECTRICAL SPECIFICATION	IS 2099-1986	Approved by: RAGHU			
8	ELECTRO TIN PLATING	12 - 15 µ	TRANSFORMER LT BUSHING (1.1KV 630AMPS)			
9	COLOUR CODE	RAL 2001	DWG NO. 09/12/2013			
10	COPPER FLAT GRADE	CuETP, Hb CONFORMING to IS:191-2007	REV - 0			
			ETB-0002			
			REV 1			

NOTE:
 1) KNURLING /SHOT BLASTING /ANY SUITABLE SURFACE TREATMENT TO ENSURE LEAK PROOF JOINT BETWEEN COPPER FLAT AND EPOXY.
 2)EPOXY CAST ASSEMBLY SHOULD NOT LEAK AT 90°C In transformer oil to IS:335-1983 AT 1 KG /SQ.MM.
 3)GLASS TRANSITION TEMPERATURE SHELL BE : 105-120°C.
 4) PRODUCT MUST BE FREE FROM SURFACE DEFECT.

NOTE: All Dimensions Are in mm