






ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION
 (Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
 ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.
 EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33
 Fax : +91 (0265) 2638382
 E-mail : erda@erda.org
 Web : http://www.erda.org



TEST REPORT

SHEET NO.: 1 OF 9

NAME & ADDRESS OF CUSTOMER M/s. Epoxy Terminal & Equipment Pvt. Ltd. Plot No : 6B, Phase -III APIIC, IDA, Pashamylaram, Medak, Telangana India 502 307	REPORT NO.: RP-1819-021280 DATE : 29/08/2018					
SAMPLE DESCRIPTION 1.1 kV 5000 A Epoxy Bushing Rated Voltage : 1.1 kV Rated Current : 5000 A Embossing : ETE Insulator Glaze : Epoxy	CUSTOMER REF. NO.: NIL DATED : 08/06/2018 <table border="1" data-bbox="850 640 1519 786"> <tr> <th>DATE OF SAMPLE RECEIPT</th> <th>DATE OF TESTING</th> </tr> <tr> <td>08/06/2018</td> <td>02/07/2018 to 13/08/2018</td> </tr> </table> SAMPLE IDENTIFICATION Serial No. : 02/17052018/A Make : M/s. Epoxy Terminal & Equipment Pvt. Ltd. Year of Mfg.: 2018 ERDA S.C. No.: ERDA-00261845		DATE OF SAMPLE RECEIPT	DATE OF TESTING	08/06/2018	02/07/2018 to 13/08/2018
DATE OF SAMPLE RECEIPT	DATE OF TESTING					
08/06/2018	02/07/2018 to 13/08/2018					
TEST DETAIL As per SHEET NO.: 2 OF 9 ENCLOSURES: DRG. No.: ETB 0010 REV 1 TEST WITNESSED BY: Mr. Ulpesh Parmar - M/s. Epoxy Terminal & Equipment Pvt. Ltd. REMARKS: As per SHEET NO.: 3 OF 9, 4 OF 9, 7 OF 9 & 8 OF 9						
 PREPARED BY	 CHECKED BY	 A.S. Khopkar APPROVED BY				
Note : 1. This report relates only to the particular sample received in good condition for testing at ERDA, Vadodara. 2. This report cannot be reproduced in part under any circumstances. 3. Publication of this report requires prior permission in writing from Director, ERDA. 4. Only the tests asked for by the customer have been carried out. 5. In case of any dispute, Vadodara will be the exclusive jurisdiction & shall be construed as where the cause has arisen. Caution: ERDA is not responsible for the authenticity of photocopied or reproduced test reports. ERDA provides support to customers for verification of the authenticity of test reports issued by ERDA.						

TC 2599748



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1819-021280

SHEET NO.: 2 OF 9

DATE : 29/08/2018

TEST DETAIL :

1 Routine Test before type test.

- 1.1 Dry power-frequency withstand voltage test
- 1.2 Measurement of partial discharge quantity

2 Type test

- 2.1 Dry lightning impulse voltage withstand test
- 2.2 Wet Power Frequency Voltage withstand test
- 2.3 Cantilever load Withstand Test

3 Routine Test after type test

- 3.1 Dry power-frequency withstand voltage test
- 3.2 Measurement of partial discharge quantity

PREPARED BY



CHECKED BY

TC 2599647



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1819-021280

SHEET NO.: 3 OF 9

DATE : 29/08/2018

Routine Test before type test

Atmospheric condition:

Dry bulb Temperature : 28.0 °C

Wet bulb Temperature : 24.0 °C

Atmospheric Pressure : 741.3 mm of Hg

Sr. No.	Test Conducted (Cl.No. & IS)	Test Requirement	Obtained Results	Remark
1.1	Dry power frequency withstand voltage test (As per customer requirement & test procedure followed as per cl. no. 11.13 of IS: 2099 - 1986)	The power frequency voltage of 5 kVrms shall be applied between the H.V. terminal of bushing & earth. The test duration shall be 60s. No flashover or puncture shall be occurred during the test.	The power frequency voltage of 5 kVrms was applied between the H.V. terminal of bushing & earth. The test duration was 60s. No flashover or puncture was occurred during the test.	Conforms
1.2	Measurement of partial discharge quantity (As per customer requirement & test procedure followed as per cl. no. 11.14 of IS: 2099 - 1986) Measurement of partial discharge quantity shall be carried out - At $1.5U_m/\sqrt{3} = 0.6$ kV - At $1.05U_m/\sqrt{3} = 1.2$ kV	Max. 10 pC Max. 100 pC	01 pC 01 pC	Conforms Conforms

PREPARED BY

CHECKED BY

TC 2599749



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1819-021280

SHEET NO.: 4 OF 9

DATE : 29/08/2018

Atmospheric condition : Dry bulb Temperature : 28.0 °C
Wet bulb Temperature : 24.0 °C
Atmospheric Pressure : 741.3 mm of Hg

2.1 Dry lightning impulse voltage withstand test

(As per customer requirement & test procedure followed as per cl. no. 11.4 of IS: 2099 - 1986)

Test Parameters:

Rated Voltage : 1.1 kV
Test Voltage : 20 kVp \pm 3%
No. of Shots to be applied: 15 +ve & 15 -ve Polarity shots

Test Observation:

Calibration Pulse : 12.556 kVp, Wave Shape: 1.455 / 46.579 μ s
No. of Shots applied : Calibration pulse, 15 +ve & 15 -ve Polarity shots
No. of Shots recorded : Calibration pulse, First & Last shot (for both polarity)

No. of Shot	Test Voltage Applied in kVp	
	Positive Polarity	Negative Polarity
1.	20.155	20.023
2.	19.495	20.438
3.	19.765	20.017
4.	19.622	19.529
5.	19.588	19.763
6.	20.335	19.954
7.	20.224	20.048
8.	19.802	19.829
9.	20.192	20.282
10.	19.945	19.748
11.	19.848	20.062
12.	19.579	19.824
13.	19.945	19.923
14.	20.209	19.786
15.	20.229	20.048

REMARKS: Conforms.

2.2 Wet Power Frequency Voltage withstand test

(As per customer requirement & test procedure followed as per cl. no. 11.3 of IS: 2099 - 1986)

Test requirement:

The test Voltage of 5 kVrms corrected to reference atmospheric condition is applied between the H.V. terminals & earth for one minute duration under artificial rainfall condition.

REMARKS: Conforms.

PREPARED BY

CHECKED BY

TC 2599656



Signature



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org


Web : http://www.erda.org



TEST REPORT NO. : RP-1819-021280
DATE : 29/08/2018

SHEET NO.: 5 of 9

DRY LIGHTNING IMPULSE VOLTAGE WITHSTAND TEST



CALIBRATION PULSE

$U_p = 12.56 \text{ kV}$

$T_1 = 1.46 \text{ μs}$

$T_2 = 46.58 \text{ μs}$

$T_c = \text{μs}$

Comment: LI RW

[Signature]

PREPARED BY



[Signature]

CHECKED BY

TC 2599386



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org




TEST REPORT NO. : RP-1819-021280

SHEET NO.: 6 of 9

DATE : 29/08/2018

DRY LIGHTNING IMPULSE VOLTAGE WITHSTAND TEST



FIRST SHOT


$U_p = 20.15 \text{ kV}$

$T_1 = 1.44 \text{ } \mu\text{s}$

$T_2 = 46.60 \text{ } \mu\text{s}$

$T_c = \text{ } \mu\text{s}$

Comment: 100% LI FW



LAST SHOT


$U_p = 20.22 \text{ kV}$

$T_1 = 1.44 \text{ } \mu\text{s}$

$T_2 = 46.63 \text{ } \mu\text{s}$

$T_c = \text{ } \mu\text{s}$

Comment: 100% LI FW



FIRST SHOT


$U_p = -20.02 \text{ kV}$

$T_1 = 1.44 \text{ } \mu\text{s}$

$T_2 = 46.67 \text{ } \mu\text{s}$

$T_c = \text{ } \mu\text{s}$

Comment: 100% LI FW



LAST SHOT

$U_p = -20.05 \text{ kV}$

$T_1 = 1.44 \text{ } \mu\text{s}$

$T_2 = 46.51 \text{ } \mu\text{s}$

$T_c = \text{ } \mu\text{s}$

Comment: 100% LI FW

PREPARED BY



CHECKED BY

TC 2599657



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO: RP-1819-021280

SHEET No. 7 OF 9

DATE : 29/08/2018

Sr. No.	Particular of Tests & Cl. No.	Requirement as per Specification	Obtained Value/ Observation	Remarks
2.3	Cantilever load withstand test [Cl. No. 11.10 of IS 2099 & as per customer's requirement] (The load of 3150 N* applied perpendicular to the axis of the bushing at the mid-point of the terminal for one minute) ERDA-00261845	The bushing shall be considered to have passed the test if there is no evidence of damage (deformation or rupture) and if it has withstood a repetition of routine tests without significant change from previous results.	No evidence of damage was observed in bushing and bushing withstood repetition of routine tests (Dry power frequency withstand voltage test and Measurement of partial discharge quantity) without any significant change from previous results.	Conforms

Note: "*" As specified by customer.

[Signature]
PREPARED BY

[Signature]
CHECKED BY



TC 2603335



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



REPORT NO.: RP-1819-021280			SHEET NO.: 8 OF 9	
DATE : 29/08/2018				
Routine Test after type test				
Atmospheric condition:				
Dry bulb Temperature : 28.0 °C				
Wet bulb Temperature : 23.0 °C				
Atmospheric Pressure : 742.5 mm of Hg				
Sr. No.	Test Conducted (Cl.No. & IS)	Test Requirement	Obtained Results	Remarks
3.1	Dry power frequency withstand voltage test (As per customer requirement & test procedure followed as per cl. no. 11.13 of IS: 2099 - 1986)	The power frequency voltage of 5 kVrms shall be applied between the H.V. terminal of bushing & earth. The test duration shall be 60s. No flashover or puncture shall be occurred during the test.	The power frequency voltage of 5 kVrms was applied between the H.V. terminal of bushing & earth. The test duration was 60s. No flashover or puncture was occurred during the test.	Conforms
3.2	Measurement of partial discharge quantity (As per customer requirement & test procedure followed as per cl. no. 11.14 of IS: 2099 - 1986) Measurement of partial discharge quantity shall be carried out - At $1.5U_m/\sqrt{3} = 0.6$ kV - At $1.05U_m/\sqrt{3} = 1.2$ kV	Max. 10 pC Max. 100 pC	01 pC 01 pC	Conforms Conforms
	Change in measurement of partial discharge quantity Change in partial discharge quantity - At $1.5U_m/\sqrt{3} = 0.6$ kV - At $1.05U_m/\sqrt{3} = 1.2$ kV	≤ 05 pC# ≤ 05 pC#	0 pC 0 pC	Conforms Conforms
Note: "#" Requirement of change in measurement of partial discharge quantity was specified by customer.				
PREPARED BY		CHECKED BY		

TC 2599750



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT NO.: RP-1819-021280


DATE : 29/08/2018

SHEET NO.: 9 of 9

PHOTOGRAPH OF TEST SAMPLE



PHOTOGRAPH OF NAME PLATE





PREPARED BY




CHECKED BY

TC 2599604



Test Report No. RP-1819-0021280
 Date: 29.10.2018
 Product: 1.1KV 5000A Epoxy Bushing
 Verified By: S.M.
 Verification of this drawing by ERDA is limited to relevant dimensional checks only. Verified dimensions are marked with.



S.NO	Description	value
1	RATED VOLTAGE	1.1 Kv
2	one min.DRY FREQUENCY WITH STAND VOLTAGE	
3	CREEPAGE DISTANCE	40 mm (min)
4	MAX CURRENT	5000A
5	COPPER FLAT DIMENSION TOLERANCE	IS 613-2008
6	COPPER AND EPOXY DIMENSION TOLERANCE	IS 2102-1993
7	ELECTRICAL SPECIFICATION	IS 2099-1986
8	ELECTRO TIN PLATING	12 - 15 μ
9	COLOUR CODE	RAL 2001
10	COPPER FLAT GRADE	CuETP HP CONFORMING to IS:191-2007

ITEM NO.	PART NUMBER	QTY.
1	ETB-0010-1	1

EPOXY TERMINAL AND EQUIPMENT PVT. LTD.
 PLOT 68, PHASE III, IDA PASHAMAILARAM, PATANCHERU, SANGAREDDY, TELANGANA - 502 307.

Date: 09/02/2018
 Drawn by: PANKAJ
 Checked by: RK
 Approved by: RAGHU

EPOXY BUSHING ASSEMBLY (1.1KV, 5000A)

DWG NO: 09/12/2013
 REV: 0

NOTE: All Dimensions Are in mm

ETB-0010	REV
1	1